

EU type examination certificate**EU-Baumusterprüfbescheinigung****CE-0085CU0338**Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	BAXI S.p.A. Via Trozzetti, 20, I-36061 Bassano del Grappa (VI)
Distributor <i>Vertreiber</i>	BAYMAK MAKINA SAN. Ve. TIC. A.S. Orhanli Beldesi Orta Mah. Ak. Sok 8, TR-34959 Tuzla/Istanbul
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Condensing combi water heater
Model <i>Modell</i>	LUNATEC PREMIX...; STARTEC PREMIX...
Countries of Destination <i>Bestimmungsländer</i>	AT, BG, CZ, EE, ES, GB, GR, HR, HU, IT, LT, LV, NL, PT, RO, SE, SK, TR
Test Reports <i>Prüfberichte</i>	type testing: 19/045/3204/033 from 17.09.2019 (EBI)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017)

Date of Expiry / File No. 17.09.2029 / 19-0626-GEE
Ablaufdatum / AZ

12.11.2019 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data
Elektrische Daten

230 V AC, 50 Hz, IPX5D

Appliance Categories Gerätekatégorien	Supply Pressures Versorgungsdrücke	Countries of Destination Bestimmungsländer	Remarks Bemerkungen
I2H	20 mbar	AT, BG, CZ, EE, ES, GB, GR, HR, HU, IT, LT, LV, PT, RO, SE, SK, TR	
I2L	25 mbar	NL	

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
LUNATEC PREMIX 24; STARTEC PREMIX 24	nominal heat output: 4,8...22 kW heat input (Hi): 4,9...22,6 (drinking water: ...24) kW	
LUNATEC PREMIX 30; STARTEC PREMIX 30	nominal heat output: 5,8...27,1 kW heat input (Hi): 6,0...28 (drinking water: ...30) kW	

Hints of Utilization /Remarks
Verwendungshinweise / Bemerkungen

flue types B23, B23P, B33, C13, C33, C43, C63, C53, C83 and C93: according to installation manual no. 7723951 with flue systems of SIT (approval no. 0476-CPR-8045) and Groppalli (approval no. 2592-CPR-0001)